

**GOVERNMENT OF ANDHRA PRADESH
STATE DISASTER RESPONSE & FIRE SERVICES DEPARTMENT**

From :
The Director General,
State Disaster Response and Fire Services,
Andhra Pradesh, Vijayawada.

To :
The Management,
M/s Kendriya Vidyalaya No-2, Wagon
workshop colony, Krishna District.

Rc.No.1075/A2/DFO/KRI/2021, Dt: 23.06.2021

Sir,

Sub: A.P. State Disaster Response and Fire Services Department-Eastern Region - Issuance of temporary No Objection Certificate to existing Building of M/s Kendriya Vidyalaya No-2, Wagon workshop colony, Krishna District -Regarding.

Ref:- Inspection committee report Rc.No.1075/A2/DFO/KRI/2021, Dt: 09.06.2021.

With reference to the above cited wherein, the departmental officers have inspected the premises of M/s Kendriya Vidyalaya No-2, Wagon workshop colony, Krishna District on 09.06.2021 and submitted the following report.

2) Particulars of Building and Building Owner:

A	Name and Address of the Building	Kendriya Vidyalaya No-2, Wagon workshop colony, Krishna District
B	Name and address of the owner/Occupier/Tenant with Telephone Nos.	Dr.P.V.S.S.S.R. Krishna, Principal. Mobile No. 9491217562
C	Height of the Building from abutting road level to terrace	04.40 Meters
D	No. of Floors	Ground Floor

3) Open spaces required and provided all round the Building:

Side	Open space Required as per GO Ms No. 119 in Meters	Open Spaces Provided in Meters	Deficit in Meters
North	05.00	15.00	Nil
South	05.00	21.00	Nil
East(Front)	05.00	57.00	Nil
West	05.00	15.00	Nil

4) The details of required and provided Means of Escape:

S. No.	Details of Means of Escape	Minimum width required as per NBC in Meters		Provided		Deficit in Meters
		No	Width	Nos.	Width in meters	
1.	Internal Staircase	Nil		01	02.00	Nil
2.	External Staircase	Nil		Nil	Nil	Nil
	Total			01	02.00	

5) The details of Occupant Load per Unit and Exit Width required and provided:

S. No.	Floor	Built-up area in Sq. Meters	Type of Occupancy	No. of Occupants as per Table-3, NBC-2016	Means of escape Required as per Management	Provided In Meters	Deficit in Meters
1	Ground	1704	Educational	426	Required 05.00 Meters Width of Doors	Provided Sufficient No. of Doors	Nil
4	Total :	1704					

6) Minimum Fire Fighting Installations required as per Table 7 Part IV of NBC - 2016 and provided by the management:

S.No.	Fire safety measures	Required	Provided	Deficit
1	Fire Extinguishers	18 Nos.	06 Nos.	12 Nos
2	Hose Reel	NR	NA	Nil
3	Terrace Tank	NR	15,000 Litres	Nil.
4	Terrace pump	NR	NA	Nil

7) The inspection committee has stated that, the management has not paid the required fire precautionary fees as well as not furnished details of date of construction of the building in order to calculate the penal interest.


8) The Regional Fire Officer, Eastern Region has scrutinized the inspection committee report and submitted that, the management may be advised to pay the statutory fee with penal interest and to provide the deficit 12 Nos. fire extinguishers.

9) However, keeping in view of Central Government School and taking into the consideration of the larger public interest and COVID-19 pandemic situation across the country, the temporary No Objection Certificate is issued to M/s Kendriya Vidyalaya No-2, Wagon workshop colony, Krishna District for a period of (01) year with a request to the school management to pay the fire precautionary fee which is mandatory.

10) This temporary No Objection Certificate for Occupancy is valid for a period of one year from the date of issue of this letter. It is the responsibility of the builder to maintain the available Fire Safety Equipment in good working condition at all the times and apply for Final No Objection Certificate for Occupancy, duly rectifying the above deficiencies and by remitting the User Charges as per G.O.Ms.No.71, Home (Prison-A) Department, dated 01-04-2010, before expiry of this No Objection Certificate.

11) This temporary No Objection Certificate is issued, subject to the outcome of O.As/W.Ps etc., if any, before Courts etc.,

Yours faithfully,


23/6/2021

For Director General,
State Disaster Response and Fire Services,
Andhra Pradesh, Vijayawada.

Copy to the District Educational Officer, Krishan District.

Copy to District Fire Officer, Krishan District.

Copy to Regional Fire Officer, Eastern Region, Vijayawada.

Note: In case of any emergency call to 101 or State Fire Control Room-9100108101.